Report Date: 9/14/2022 Report Time: 4:06 PM EDT

Region II Hotline Log Entry Information

Data ID: 2294984

Date Of Report: 1/25/2018 **NRC** #: 1202791 **State** #: 1709763 **ERNS** #:

Material Type: Oil Receiver: Hriczko

Material / Amount: OIL, MISC: TRANSFORMER (100 GALLON(S));

Location: Street:

City: NEW YORK

County: NEW YORK (MANHATTAN)

State: NY Latitude: Longitude:

Source of Pollution: CONSOLIDATED EDISON COMPANY OF NEW YORK

Water Body: WATER WITHIN STRUCTURE

State Or EPA Responded:RP responseInitial EPA Action:RP responseStatus:2 - Closed

URL:

Associated Action Reports

DataID: 1124367

 Date: 1/25/2018
 Time: 10:12

 Duty Officer/Responder Name: Reddy
 NRC Report #: 1202791
 Hotline Log DataID: 2294984

 Action Information

100001111011111011

Description: Osc Reddy spoke to Felix Cancel of ConEd. ConEd is deploying a frac tank to remove water and oil and removing and

replacing faulty equipment.

Follup-Up:

Person Contacted

Name: Felix Cancel
Organization: ConEd
Phone #: 212-580-8383

NRC Spill Report

NATIONAL RESPONSE CENTER 1-800-424-8802

GOVERNMENT USE ONLYGOVERNMENT USE ONLY***

Information released to a third party shall comply with any

applicable federal and/or state Freedom of Information and Privacy Laws

Incident Report # 1202791

INCIDENT DESCRIPTION

*Report taken by: MST1 ERIC MERRITT at 09:25 on 25-JAN-18

Incident Type: FIXED

Incident Cause: EQUIPMENT FAILURE
Affected Area: WATER WITHIN STRUCTURE

Incident was discovered on 25-JAN-18 at 09:10 local incident time.

Affected Medium: WATER UNDERGROUND TRANSFORMER VAULT

REPORTING PARTY

Name: FELIX CANCEL

Organization: CONSOLIDATED EDISON COMPANY OF NEW YORK

Address: 31ST ST AND 20TH AVE

ASTORIA, NY 11105 Email Address: cancelf@coned.com

PRIMARY Phone: (212)5808383

Type of Organization: PUBLIC UTILITY

SUSPECTED RESPONSIBLE PARTY

Name: FELIX CANCEL

Organization: CONSOLIDATED EDISON COMPANY OF NEW YORK

ASTORIA, NY 11105

PRIMARY Phone: (212)5808383

Type of Organization: PUBLIC UTILITY

INCIDENT LOCATION

4 NEW YORK PLAZA County: NEW YORK (MANHATTAN)

City: NEW YORK State: NY

RELEASED MATERIAL(S) Official Material Name: OIL, MISC: TRANSFORMER

CHRIS Code: OTF Also Known As:

Qty Released: 100 GALLON(S) Oty in Water: 100 GALLON(S)

DESCRIPTION OF INCIDENT

CALLER STATED THAT AN UNDER GROUND TRANSFORMER SUFFERED AN EQUIPMENT FAILURE RESULTING IN THE RELEASE OF 100 GALLONS OF NON PCB MINERAL OIL TO THE WATER WITHIN THE UNDERGROUND STRUCTURE (SUBMERSIBLE TRANSFORMER VAULT)

INCIDENT DETAILS

Package: N/A Building ID:

Type of Fixed Object: TRANSFORMER Power Generating Facility: UNKNOWN

Generating Capacity:

Type of Fuel:

NPDES:

NPDES Compliance: UNKNOWN

---WATER INFORMATION---

Body of Water: WATER WITHIN STRUCTURE

Tributary of:

Nearest River Mile Marker:

Water Supply Contaminated: UNKNOWN

IMPACT

Fire Involved: NO Fire Extinguished: UNKNOWN

NO INJURIES: Hospitalized: Empl/Crew: Passenger: FATALITIES: NO Empl/Crew: Passenger: Occupant:

EVACUATIONS: NO Who Evacuated: Radius/Area:

Damages: NO

> Hours Direction of

Closure Type Description of Closure Closed Closure

Air:

Road: N Major

Artery: N

Waterway:

Track:

Passengers Transferred: NO Environmental Impact: NO

Media Interest: NONE Community Impact due to Material:

REMEDIAL ACTIONS

WORKING TO GET FRAC TANK IN PLACE. WORKING TO REMOVE AND REPLACE FAULTY EQUIPMENT

Release Secured: UNKNOWN

Release Rate:

Estimated Release Duration:

WEATHER

ADDITIONAL AGENCIES NOTIFIED

Federal:

State/Local: DEC State/Local On Scene:

1709763 State Agency Number:

NOTIFICATIONS BY NRC

CENTERS FOR DISEASE CONTROL (GRASP)

25-JAN-18 09:32 (770)4887100

DHS NOC (NOC)

09:32 (202) 2828114 25-JAN-18

DHS DEFENSE THREAT REDUCTION AGENCY (CHEMICAL AND BIOLOGICAL TECHNOLOGIES DEPARTMENT)

25-JAN-18 09:32 (703)7673477

DHS INFRSTR SECURITY COMPLIANCE DIV (REGION 2)

25-JAN-18 09:32 (202) 4655909

DOT CRISIS MANAGEMENT CENTER (MAIN OFFICE)

25-JAN-18 09:32 (202) 3661863

U.S. EPA II (MAIN OFFICE)

25-JAN-18 09:41 (732)3214370 HRICZO

USCG NATIONAL COMMAND CENTER (MAIN OFFICE)

25-JAN-18 09:32 (202)3722100

NATIONAL INFRASTRUCTURE COORD CTR (MAIN OFFICE)

25-JAN-18 09:32 (202)2829201

NJ OFC HMLND SECURITY & PREPAREDNES (COMMAND CENTER)

25-JAN-18 09:32 (609)9636817

NJ STATE POLICE (MARINE SERVICES BUREAU)
25-JAN-18 09:32 (609)9636900

NOAA RPTS FOR NY (MAIN OFFICE)
25-JAN-18 09:32 (206)5264911

NY STATE DEC SPILL HOTLINE (MAIN OFFICE)
25-JAN-18 09:32 (518)4577362

REPORTING PARTY (RP SUBMITTER)
25-JAN-18 09:32

SECTOR NEW YORK (COMMAND CENTER)

15 5111 15 55151 (517)115555

USCG DISTRICT 1 (COMMAND CENTER)
25-JAN-18 09:32 (617)2238555

25-JAN-18 09:46 (718)3544356

ADDITIONAL INFORMATION

SMITH

*** END INCIDENT REPORT # 1202791 ***
Report any problems by calling 1-800-424-8802
PLEASE VISIT OUR WEB SITE AT http://www.nrc.uscg.mil